

CERTIFICATE OF COMPLIANCE

Certificate Number 20150713-E222308
Report Reference E222308-20150625
Issue Date 2015-July-13

Issued to: G M INTERNATIONAL S R L
VIA SAN FIORANO 70 20852 VILLASANTA MB ITALY

**This is to certify that
representative samples of**

PROCESS CONTROL EQUIPMENT FOR USE IN
HAZARDOUS LOCATIONS, PROCESS CONTROL
EQUIPMENT FOR USE IN ZONE CLASSIFIED
HAZARDOUS LOCATIONS

See addendum page

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:
Additional Information:

See addendum page

See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20150713-E222308
Report Reference E222308-20150625
Issue Date 2015-July-13

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

USL, CNL Associated Apparatus for use in Unclassified Locations or Class I, Division 2, Groups A, B, C, and D T4 and Class I, Zone 2, AEx nA [ja Ga] IIC T4 Gc, and Ex nA [ja Ga] IIC T4 Gc Hazardous Locations.

Models D5011, followed by S or D, provides intrinsically safe outputs for use in Class I, Division 1, Groups A, B, C, and D, Class II, Division 1, Groups E, F, and G, Class III and Class I, Zone 0, Group IIC, Zone 20, Group IIIC Hazardous Locations when installed in accordance with manufacturer's control drawing no. ISM0272.

Models D5014, followed by S or D, provides intrinsically safe outputs for use in Class I, Division 1, Groups A, B, C, and D, Class II, Division 1, Groups E, F, and G, Class III and Class I, Zone 0, Group IIC, Zone 20, Group IIIC Hazardous Locations when installed in accordance with manufacturer's control drawing no. ISM0273.

Models D5034, followed by S or D, provides intrinsically safe outputs for use in Class I, Division 1, Groups A, B, C, and D, Class II, Division 1, Groups E, F, and G, Class III and Class I, Zone 0, Group IIC, Zone 20, Group IIIC Hazardous Locations when installed in accordance with manufacturer's control drawing no. ISM0276.

UL 913, Intrinsically Safe Apparatus and Associated Apparatus for Use in Class I, II, and III, Division 1, Hazardous (Classified) Locations
ANSI/ISA 12.12.01-2013, Issued 2013-06-03, Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations
UL 60079-0, Explosive atmospheres – Part 0: Equipment – General requirements
UL 60079-11, Explosive Atmospheres – Part 11: Equipment Protection by Intrinsic Safety “i”
UL 60079-15, Explosive atmospheres – Part 15: Equipment protection by type of protection “n”
UL 61010-1 Electrical Equipment for Measurement, Control, and Laboratory Use; Part 1: General Requirements
CAN/CSA C22.2 No. 157-92, , Intrinsically Safe and Non-incendive Equipment for Use in Hazardous Locations
CAN/CSA C22.2 No. 213-M1987, Issued 1987-03, Non-incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations
CAN/CSA-C22.2 No. 60079-0:11, Explosive atmospheres — Part 0: Equipment — General requirements
CAN/CSA-C22.2 No. 60079-11:14, Explosive atmospheres — Part 11: Equipment protection by intrinsic safety “i”
CAN/CSA C22.2 No. 60079-15:12, Issued 2012-01, Electrical apparatus for explosive gas atmospheres — Part 15: Construction, test and marking of type of protection “n” electrical apparatus



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20150713-E222308
Report Reference E222308-20150625
Issue Date 2015-July-13

CAN/CSA C22.2 No. 61010-1-12, "Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use - Part 1: General Requirements"



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

