

CERTIFICATE OF COMPLIANCE

Certificate Number E222308
Report Reference E222308-20210226
Date 2021-March-18

Issued to: G M INTERNATIONAL S R L
Via G. Mameli, 53-55
VillasantaMb 20852 IT

**This is to certify that
representative samples of**

**PROCESS CONTROL EQUIPMENT FOR USE IN
HAZARDOUS LOCATIONS - COMPONENT**

Open Type – DIN Rail Termination Boards 1 position,
models TBE-D5001-HRT-003 and TBE-D5001-HRT-xxx
(xxx ≥ 004) where xxx are any alpha-numeric characters for
use in Class I, Division 2, Groups A, B, C and D, Hazardous
Locations.

Have been investigated by UL in accordance with the
component requirements in the Standard(s) indicated on
this Certificate. UL Recognized components are incomplete
in certain constructional features or restricted in
performance capabilities and are intended for installation in
complete equipment submitted for investigation to UL LLC.

Standard(s) for Safety: See Addendum Page for Standards

Additional Information: See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information

This Certificate of Compliance does not provide authorization to apply the UL Recognized Component Mark.
Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Recognized Component Mark should be considered as being UL Certified
and covered under UL's Follow-Up Services.

Look for the UL Recognized Component Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/about/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number E222308
Report Reference E222308-20210226
Date 2021-March-18

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

UL 61010-1 Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use - Part 1: General Requirements
CAN/CSA C22.2 No. 61010-1-12 Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use - Part 1: General Requirements
UL 121201 Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations
CSA C22.2 No. 213-17 Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/about/locations/>

