

EU-TYPE EXAMINATION CERTIFICATE



- [1]
- [2]
- [3]
- [4]
- [5]
- [6]
- [7]
- [8]
- [9]
- [10]
- [11]
- [12]

**Equipment or Protective System intended for use
in Potentially Explosive Atmospheres
Directive 2014/34/EU**

EU-Type Examination Certificate Number: **UL 22 ATEX 2892X Rev. 0**

Product: **Transmitter Current Repeater, D5016**-*****

Manufacturer: **G.M. International srl**

Address: **Via G. Mameli, 53-55S, Villasanta, MB, 20852 Italy**

This product and any acceptable variation thereto are specified in the schedule to this certificate and the documents therein referred to.

UL International Demko A/S, notified body number 0539 in accordance with Article 17 of the Council Directive 2014/34/EU of 26 February 2014, certifies that this product has been found to comply with the Essential Health and Safety Requirements relating to design and construction of products intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in confidential report no. **DK/ULD/ExTR22.0037/00.**

Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

EN IEC 60079-0:2018 EN IEC 60079-7:2015 + A1:2018 EN 60079-11:2012 EN 50303:2000

If the sign "X" is placed after the certificate number, it indicates that the product is subject to special conditions for safe use specified in the schedule to this certificate.

This EU-Type Examination Certificate relates only to the design and construction of the specified product. Further requirements of the Directive apply to the manufacturing process and supply of this product. These are not covered by the certificate.

The marking of the product shall include the following:

II 3(1) G Ex ec [ia Ga] IIC T4 Gc
 II (1) D [Ex ia Da] IIIC
 I (M1) [Ex ia Ma] I

Certification Manager
Jan-Erik Storgaard

This is to certify that the sample(s) of the Product described herein ("Certified Product") has been investigated and found in compliance with the Standard(s) indicated on this Certificate, in accordance with the ATEX Product Certification Program Requirements. This certificate and test results obtained apply only to the product sample(s) submitted by the Manufacturer. UL did not select the sample(s) or determine whether the sample(s) provided were representative of other manufactured product. UL has not established Follow-Up Service or other surveillance of the product. The Manufacturer is solely and fully responsible for conformity of all product to all applicable Standards, specifications, requirements or Directives. The test results may not be used, in whole or in part, in any other document without UL's prior written approval.

Date of issue: 2022-12-19

Notified Body UL International Demko A/S, Borupvang 5A, 2750 Ballerup, Denmark
Tel. +45 44 85 65 65, info.dk@ul.com, www.ul.com



[13]

[14]

Schedule

EU-TYPE EXAMINATION CERTIFICATE No.

UL 22 ATEX 2892X Rev. 0

[15]

Description of Product

D5016 series are associated apparatus and increased safety electrical apparatus, designed as single/double channel galvanic isolators, to interface intrinsically safe field devices located in potentially explosive atmospheres with non-intrinsically safe measuring and process control equipment located in non-explosive atmospheres. They are packaged in a plastic enclosure suitable for installation on EN/IEC60715 TH 35 DIN-Rail, with or without Power Bus connector, or on Termination Board provided with customer dedicated connection.

D5016 modules can be located in non-explosive atmospheres or potentially explosive gas atmospheres. Electrical connections are accommodated by plug-in removable terminal block or with customer dedicated connector when installed on Termination Board.

Nomenclature:

D5016	S	S	-xxx
I	II	III	IV

I – Model designation:

D5016 – I.S. SIL3 4-Wire HART® Transmitter Current Repeater

II – No. of Channel:

S – 1 channel
D – 2 channel

III – Output type:

S – Source output
K – Sink output

IV: Configuration – Optional:

-xxx – Any alpha-numeric character denoting pre-delivery testing or configuration requested by end-user. No changes are made to construction of the device.

The optical radiation output of the product with respect to explosion protection, according to Annex II clause 1.3.1 of the Directive 2014/34/EU is covered in this certificate based on Exception 1) to the scope of EN 60079-28:2015.

Temperature range

The ambient temperature range is -40°C to +70°C.

Electrical data

Model	Supply voltage (Terminals 9-10)	Current consumption	Power consumption	Input	Output
D5016SS-xxx	24V dc (18-30V dc)	33 mA	1.0W max.	4-20mA Terminals 7-8	Source output 4-20mA Terminals 1-2
D5016SK-xxx		20 mA	0.6W max.		Sink output 4-20mA 2-30V dc Terminals 1-2
D5016DS-xxx		57 mA	1.6W max.	4-20mA Terminals 7-8 and 9-10	Source output 4-20mA Terminals 1-2 and 3-4
D5016DK-xxx		31 mA	0.9W max.		Sink output 4-20mA 2-30V dc Terminals 1-2 and 3-4

Other (I/O): 1 x BUS

Intrinsically safe specifications:

U_m: 250V rms or dc

Terminals		Group	Co [μF]	Lo [mH]	Lo/Ro [μH/Ω]
7-8 (Ch1) 9-10 (Ch2)	U _o : 8.8V I _o : 0 mA P _o : 0 mW U _i : 30V I _i : 100mA C _i : 1.1nF L _i : 0nH	IIC	5.4	1000	N/A
		IIB or IIIC	45.9	1000	N/A
		IIA	729.9	1000	N/A
		I	999.9	1000	N/A

Routine tests

Each piece of equipment shall be subjected to the routine tests for transformers in accordance with clause 11.2 of EN 60079-11. A test voltage of 1500V rms shall be applied between T300 and T400 pins 5-6 and pins 1-4 for a minimum of 60 s without breakdown resulting in more than 5 mA rms flowing. Alternatively, a test voltage of 1800V rms for a minimum of 1 s may be used.



[13]

[14]

Schedule

EU-TYPE EXAMINATION CERTIFICATE No.

UL 22 ATEX 2892X Rev. 0

[16] Descriptive Documents
The scheduled drawings are listed in the report no. provided under item no. [8] on page 1 of this EU-Type Examination Certificate.

[17] Specific conditions of use:

- For installations in which both the Ci and Li of the connected apparatus exceeds 1% of the Co and Lo parameters of the Associated Apparatus (excluding the cable), then 50% of Co and Lo parameters are applicable and shall not be exceeded. The reduced capacitance of the external circuit (including the cable) shall not exceed 1uF for Groups I, IIA and IIB and 600 nF for Group IIC
- The equipment shall only be used in an area of at least pollution degree 2, as defined in EN 60664-1.
- For hazardous location, the unit shall be installed in an enclosure that provides a minimum ingress protection of IP54 in accordance with EN 60079-0, that must have a door or cover accessible only by the use of a tool.

[18] Essential Health and Safety Requirements
The Essential Health and Safety Requirements (EHSRs) covered by the standards listed at item 9.

Additional information

The trademark  will be used as the company identifier on the marking label.

The manufacturer shall inform the notified body concerning all modifications to the technical documentation as described in Annex III to Directive 2014/34/EU of the European Parliament and the Council of 26 February 2014.