



**Translation**

**(1) EC-Type Examination Certificate**

**(2) - Directive 94/9/EC -**

**Equipment and protective systems intended for use  
in potentially explosive atmospheres**

**(3) BVS 06 ATEX E 101 X**

**(4) Equipment:** Multiplexer System type D2000M

**(5) Manufacturer:** GM International S.R.L.

**(6) Address:** 20058 Villasanta (MI), Italy

**(7)** The design and construction of this equipment and any acceptable variation thereto are specified in the schedule to this type examination certificate.

**(8)** The certification body of EXAM BBG Prüf- und Zertifizier GmbH, notified body no. 0158 in accordance with Article 9 of the Directive 94/9/EC of the European Parliament and the Council of 23 March 1994, certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmospheres, given in Annex II to the Directive.

The examination and test results are recorded in the test and assessment report BVS PP 06.2133 EG.

**(9)** The Essential Health and Safety Requirements are assured by compliance with:

EN 50014:1997+A1-A2 General requirements EN 50284:1999 Equipment Group II Category 1G

EN 50020:2002 Intrinsic safety 'i'

DIN EN 60079-25:2004 IS-systems EN 60079-27:2006 Fieldbus systems

(IEC 60079-25:2003) (IEC 60079-27:2005) (FISCO / FNICO)

**(10)** If the sign "X" is placed after the certificate number, it indicates that the equipment is subject to special conditions for safe use specified in the schedule to this certificate.

**(11)** This EC-Type Examination Certificate relates only to the design, examination and tests of the specified equipment in accordance to Directive 94/9/EC.

Further requirements of the Directive apply to the manufacturing process and supply of this equipment. These are not covered by this certificate

**(12)** The marking of the equipment shall include the following:

**Ex II (1)G [EEx ia] IIC (power supply D2050M-\*\*\*)**  
**II (1) 2G EEx ia IIC T4 (field devices D2030M-\*\*\* / D2010M-\*\*\* / D2011M-\*\*\*)**

**EXAM BBG Prüf- und Zertifizier GmbH**

Bochum, dated 22. November 2006

Signed: Dr. Jockers

Signed: Dr. Eickhoff

Certification body

Special services unit

(13)

Appendix to

(14)

## EC-Type Examination Certificate

### BVS 06 ATEX E 101 X

(15) 15.1 Subject and type

Multiplexer System type D2000M

The multiplexer system comprises a power supply and several field devices as listed below:

Power Supply:

Number	designation / function	type
1	Power Supply - Gateway	D2050M-***
Field Devices:	(total number of devices 4)	
Number	designation / function	type
up to 4	32 channel Digital Input Front End	D2030M-***
up to 4	16 channel Analogue Input Front End each optionally combined with up to 3 16 channel Analogue Input Expander	D2010M-*** D2011M-***

In the full designation the "\*\*\*\*" are replaced by numbers / letters indicating details of function not relevant to Ex.

#### 15.2 Description

Power Supply - Gateway type D2050M-\*\*\* provide dual channel two wire intrinsically safe power supply for fieldbus apparatus according to FISCO Model and bi-directional transmission of fieldbus data signals between non intrinsically safe and intrinsically safe fieldbus circuits.

Electronic components of the power supply are arranged on a printed-circuit-board (PCB) packaged in the bottom part of a plastic enclosure suitable for installation on T35 DIN Rails. The PCBs are protected by means of a metallic cover.

Terminals for the intrinsically safe fieldbus supply and signal circuits and for the non intrinsically safe circuits are arranged on the front side of the enclosure.

Power Supply - Gateway type D2050M-\*\*\* provide safe galvanic separation between intrinsically safe fieldbus supply and signal circuits and non intrinsically safe fieldbus signal circuits and power supply on the PCB up to a sum of peak values of rated voltages of 375 V.

The Power Supply - Gateway type D2050M-\*\*\* is designated for installation in the safe area or optionally in the hazardous area (apparatus category 2G), mounted in an enclosure providing a suitable type of explosion protection.

The 32 Channel Digital Input type D2030M-\*\*\*, the 16 Channel Analogue Input type D2010M-\*\*\* or the 16 Channel Analogue Input Expander type D2011M-\*\*\* consist of a plastic enclosure suitable for installation on DIN Rails providing electronic components mounted on printed-circuit-boards (PCB).

Terminals for the intrinsically safe circuits (supply + communication and measuring circuits) are arranged on the front side of the enclosure.

Control- and display facilities (LEDs and configuration jumpers) are arranged on the front panel.

Different IS circuits are galvanically separated from each other or interconnected according to the following table.

Apparatus	galvanic separation between		
	supply + communication line 1 and line 2	measuring circuits and supply + communication	measuring circuits from each other
D2030M-***	yes	yes	no
D2010M-***	yes	yes	no
D2011M-***	yes )*	yes	no
)* interconnected to D2010M-***; D2011M-*** supplied by D2010M-***			

### 15.3 Parameters

#### 15.3.1 Power Supply-Gateway Type D2050M-\*\*\*

##### 15.3.1.1 Non intrinsically safe circuits

Parameters		Power supply	input / output signal circuits
Voltage	$U_n$	DC 24 V (20 - 30 V)	
	$U_m$	AC 250 V	AC 250 V
Power consumption	$P_n$	8.5 W	
Terminals		M4	M2, M3, J3, J4

##### 15.3.1.2 Intrinsically safe supply- and fieldbus circuits type of protection EEx ia IIC

Parameters	Line 1	Line 2
Voltage $U_o$	DC 15 V	DC 15 V
Current $I_o$	210 mA	210 mA
Supply current at 15 V	116 mA	116 mA
Power $P_o$	1736 mW	1736 mW
Current limiting resistor	163 $\Omega$	163 $\Omega$
Characteristics	trapezoidal	
maximum cable length	see 15.3.3	see 15.3.3
Terminals	M1A	M1B

##### 15.3.1.3 Ambient temperature range $-40^{\circ}\text{C} \leq T_a \leq 60^{\circ}\text{C}$

#### 15.3.2 Intrinsically safe field devices

##### 15.3.2.1 Power supply

Parameters	D2010M-***, D2010M-*** + D2011M-***, D2030M-***	
	Line 1	Line 2
Voltage $U_i$	DC 15 V	DC 15 V
Current $I_i$	215 mA	215 mA
Power $P_i$	1755 mW	1755 mW
Terminals	M10A	M10B
Terminator	$1.2 \mu\text{F} + 100 \Omega$	$1.2 \mu\text{F} + 100 \Omega$
Terminals	M9A	M9B

## 15.3.2.2 Measuring circuits

Parameters	D2010M-*** + D2011M-***		D2030M-***	
	Channel 1 - 64 ) <sup>1</sup>	Channel 1- 32		
Voltage U <sub>o</sub>	DC 10,7 V		DC 10,7 V	
Current I <sub>o</sub>	7 mA		14 mA	
Power P <sub>o</sub>	19 mW		38 mW	
max. external capacitance C <sub>o</sub>	IIC	2.23 µF	IIC	2.23 µF
	IIB	15.6 µF	IIB	15.6 µF
	IIA	69 µF	IIA	69 µF
max. external inductance L <sub>o</sub>	IIC	725 mH	IIC	181 mH
	IIB	2902 mH	IIB	725 mH
	IIA	5804 mH	IIA	1451 mH
max. inductance / resistance ratio L <sub>o</sub> /R <sub>o</sub>	IIC	1.888 mH/Ω	IIC	946.5 µH/Ω
	IIB	7.552 mH/Ω	IIB	3.786 mH/Ω
	IIA	15.105 mH/Ω	IIA	7.572 mH/Ω
Characteristics	linear			
Terminals	M1 to M8	M1 to M8		
<sup>1</sup> channel 1 - 16 D2010M-*** stand alone; channel 17 - 32 first D2011M-*** expander; channel 33 - 48 second D2011M-*** expander; channel 49 - 64 third D2011M-*** expander				

15.3.2.3 Ambient temperature range  $-40^{\circ}\text{C} \leq T_a \leq 60^{\circ}\text{C}$ 

## 15.3.3 Maximum cable length

for interconnection cable between Power Supply - Gateway type D2050M-\*\*\* and Field Devices type D2030M-\*\*\* and/or type D2010M-\*\*\* the following parameters apply:

- resistance per unit length  $15 \Omega/\text{km} \leq R' \leq 150 \Omega/\text{km}$
- inductance per unit length  $0.4 \text{ mH/km} \leq L' \leq 1 \text{ mH/km}$
- capacitance per unit length (including screen)  $45 \text{ nF/km} \leq C' \leq 200 \text{ nF/km}$
- $C' = C'_{\text{wire/wire}} + 0,5 \times C'_{\text{wire/screen}}$  fieldbus-circuit insulated
- $C' = C'_{\text{wire/wire}} + C'_{\text{wire/screen}}$  screen connected to the output of the fieldbus power supply
- maximum length of each spur cable 60 m (Group IIC / IIB)
- maximum permissible cable length including length of all spur cables is 1000 m (Group IIC) or 5000 m (Group IIB) respectively.

(16) Test and assessment report

BVS PP 06.2133 EG as of 22.11.2006

(17) Special conditions for safe use

- 17.1 Power Supply - Gateway type D2050M-\*\*\*
  - 17.1.1 Installation in the safe area.
    - 17.1.1.1 Wiring shall satisfy the conditions of clause 6.4.11 and clause 7.6.e of EN 50020:2002.
    - 17.1.1.2 Clearances of uninsulated conductors of intrinsically safe circuits to grounded metal parts of the enclosure shall be at least 3 mm, and to uninsulated conductors of non-intrinsically safe circuits of other apparatus shall comply with the values given in table 4 EN 50020:2002 as a minimum.
    - 17.1.1.3 Terminals or connectors for the intrinsically safe fieldbus supply and signal circuits shall be arranged according to clause 6.3.1 or 6.3.2 of EN 50020:2002 respectively.
  - 17.1.2 Installation in the hazardous area requiring apparatus category 2G.
    - 17.1.2.1 The Power Supply - Gateway type D2050M-\*\*\* shall be mounted in an enclosure providing a suitable type of explosion protection.
    - 17.1.2.2 Mounting in an enclosure providing a suitable type of explosion protection, shall be submitted to separate assessment and/or certification procedure.
  - 17.1.3 For interconnection cable between Power Supply - Gateway type D2050M-\*\*\* and Field Devices type D2030M-\*\*\* and/or type D2010M-\*\*\* the parameters in 15.3.3 apply.


17.2 Intrinsically safe apparatus type D2030M-\*\*\* / D2010M-\*\*\* / D2011M-\*\*\*:  
The backplane of the field devices type D2030M-\*\*\* / D2010M-\*\*\* / D2011M-\*\*\* shall be protected against electrostatic charge by means of suitable installation on DIN rails.


---

We confirm the correctness of the translation from the German original.  
In the case of arbitration only the German wording shall be valid and binding.

44809 Bochum, 22.11.2006  
BVS-Scha/Mi A 20060182

**EXAM BBG Prüf- und Zertifizier GmbH**

  
Jackson  
Certification body

  
Cirlleff  
Special services unit

## Translation

# 1. Supplement to the EC-Type Examination Certificate

- (2) Equipment and protective systems intended for use in potentially explosive atmospheres - Directive 94/9/EC  
Supplement accordant with Annex III number 6
- (3) No. of EC-Type Examination Certificate: **BVS 06 ATEX E 101 X**
- (4) Equipment: **Multiplexer System type D2000M**
- (5) Manufacturer: **G.M. International S.R.L.**
- (6) Address: **Via San Fiorano 70, 20852 Villasanta (MB), Italy**
- (7) The design and construction of this equipment and any acceptable variation thereto are specified in the appendix to this supplement.
- (8) The certification body of DEKRA EXAM GmbH, notified body no. 0158 in accordance with Article 9 of the Directive 94/9/EC of the European Parliament and the Council of 23 March 1994, certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmospheres, given in Annex II to the Directive. The examination and test results are recorded in the Test and Assessment Report BVS PP 06.2133 EG.
- (9) The Essential Health and Safety Requirements are assured by compliance with:  
**EN 60079-0:2012 General requirements**  
**EN 60079-11:2012 Intrinsic safety 'i'**  
**EN 60079-25:2010 Intrinsically safe electrical systems**  
**EN 60079-26:2007 Equipment with equipment protection level (EPL) Ga**
- (10) If the sign "X" is placed after the certificate number, it indicates that the equipment is subject to special conditions for safe use specified in the appendix to this certificate.
- (11) This supplement to the EC-Type Examination Certificate relates only to the design, examination and tests of the specified equipment in accordance to Directive 94/9/EC.  
Further requirements of the Directive apply to the manufacturing process and supply of this equipment. These are not covered by this certificate.
- (12) The marking of the equipment shall include the following:



**II (1)G [Ex ia Ga] IIC**

(Power Supply - Gateway D2050M-\*\*\*)

**II (1)2G Ex ia [ia Ga] IIC T4 Gb**

(Field Devices D2030M-\*\*\* / D2010M-\*\*\* / D2011M-\*\*\*)

DEKRA EXAM GmbH  
Bochum, dated 2013-10-21

Signed: Dr. Eickhoff

Certification body

Signed: Dr. Wittler

Special services unit

- (13) Appendix to
- (14) **1. Supplement to the EC-Type Examination Certificate  
BVS 06 ATEX E 101 X**
- (15) 15.1 Subject and type

Multiplexer System type D2000M  
(Type code of devices: no change)

#### 15.2 Description

The Multiplexer System can be modified according to the descriptive documents as mentioned in the pertinent Test and Assessment Report.

The status of applied standards has been subjected to update.

#### 15.3 Parameters

Parameters specified in basic certificate remain valid without change.

- (16) Test and Assessment Report

BVS PP 06.2133 EG as of 2013-10-21

- (17) Special conditions for safe use

- 17.1 Power Supply - Gateway type D2050M-\*\*\*
  - 17.1.1 Installation in the safe area.
    - 17.1.1.1 Wiring shall satisfy the conditions of clause 6.3.12 and clause 7.6.e of EN 60079-11:2012.
    - 17.1.1.2 Clearances of un-insulated conductors of intrinsically safe circuits to grounded metal parts of the enclosure shall be at least 3 mm, and to un-insulated conductors of non-intrinsically safe circuits of other apparatus shall comply with the values given in table 5 EN 60079-11:2012 as a minimum.
    - 17.1.1.3 Terminals or connectors for the intrinsically safe fieldbus supply and signal circuits shall be arranged according to clause 6.2.1 or 6.2.2 of EN 60079-11:2012 respectively.
  - 17.1.2 Installation in hazardous area requiring EPL Gb equipment
    - 17.1.2.1 The Power Supply - Gateway type D2050M-\*\*\* shall be mounted in an enclosure providing a suitable type of explosion protection.
    - 17.1.2.2 Mounting in an enclosure providing a suitable type of explosion protection, shall be submitted to separate assessment and / or certification procedure.
  - 17.1.3 For interconnection cable between Power Supply - Gateway type D2050M-\*\*\* and Field Devices type D2030M-\*\*\* and / or type D2010M-\*\*\* the parameters in clause 15.3.3 of basic certificate apply.
- 17.2 Intrinsically safe apparatus type D2030M-\*\*\* / D2010M-\*\*\* / D2011M-\*\*\*.
  - The backplane of the field devices type D2030M-\*\*\* / D2010M-\*\*\* / D2011M-\*\*\* shall be protected against electrostatic charge by means of suitable installation on DIN rails, if not mounted inside stainless steel enclosure of type series GM23xx.

---

We confirm the correctness of the translation from the German original.  
In the case of arbitration only the German wording shall be valid and binding.

DEKRA EXAM GmbH  
44809 Bochum, 2013-10-21  
BVS-Scha/Mu A 20130033



Certification body



Special services unit

## Translation

# EU-Type Examination Certificate Supplement 2

Change to Directive 2014/34/EU

1 Equipment intended for use in potentially explosive atmospheres

Directive 2014/34/EU

2 EU-Type Examination Certificate Number: **BVS 06 ATEX E 101 X**

3 Product: **Multiplexer System type D2000M**

4 Manufacturer: **G.M. International S.R.L.**

5 Address: **Via Mameli 53/55, 20852 Villasanta (MB), Italy**

6 This supplementary certificate extends EC-Type Examination Certificate No. BVS 06 ATEX E 101 X to apply to products designed and constructed in accordance with the specification set out in the appendix of the said certificate but having any acceptable variations specified in the appendix to this certificate and the documents referred to therein.

7 DEKRA EXAM GmbH, Notified Body number 0158, in accordance with Article 17 of Directive 2014/34/EU of the European Parliament and of the Council, dated 26 February 2014, certifies that this product has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of products intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in the confidential Report No. BVS PP 06.2133 EU.

8 Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

EN 60079-0:2012 + A11:2013 **General requirements**

EN 60079-11:2012 **Intrinsic Safety "i"**

EN 60079-25:2010 **Intrinsically safe systems**

9 If the sign "X" is placed after the certificate number, it indicates that the product is subject to the Special Conditions for Use specified in the appendix to this certificate.

10 This EU-Type Examination Certificate relates only to the design and construction of the specified product. Further requirements of the Directive apply to the manufacturing process and supply of this product. These are not covered by this certificate.

11 The marking of the product shall include the following:

II (1)G [Ex ia Ga] IIC (power supply)  
II (1)2G Ex ia [ia Ga] IIC T4 Gb (field devices)

DEKRA EXAM GmbH  
Bochum, 2018-05-29

Signed: Jörg Koch

Certifier

Signed: Dr Michael Wittler

Approver

13 **Appendix**14 **EU-Type Examination Certificate****BVS 06 ATEX E 101 X  
Supplement 2**15 **Product description**15.1 **Subject and type**

Multiplexer System type D2000M

The multiplexer system comprises of a power supply and several field devices as listed below:

Power Supply		
number	designation / function	type
1	Power Supply – Gateway	D2050M-***
Field Devices (total number of devices 4)		
number	designation / function	type
up to 4	32 channel Digital Input Front End	D2030M-***
up to 4	16 channel Analogue Input Front End each optionally combined with up to 3	D2010M-***
	16 channel Analogue Input Expander(s)	D2011M-***

In the full designation the "\*\*\*\*" are replaced by numbers / letters indicating details of function not relevant to Ex.

15.2 **Description**

With this supplement the certificate is changed to Directive 2014/34/EU.

(Annotation: In accordance with Article 41 of Directive 2014/34/EU, EC-Type Examination Certificates referring to 94/9/EC that were in existence prior to the date of application of 2014/34/EU (20 April 2016) may be referenced as if they were issued in accordance with Directive 2014/34/EU. Supplementary Certificates to such EC-Type Examination Certificates, and new issues of such certificates, may continue to bear the original certificate number issued prior to 20 April 2016.)

**Reason for the supplement:**

- Change to Directive 2014/34/EU
- Update of manufacturer's address
- Update of applied standards as listed in item 9
- Update of the standard EN 60079-26:2007 (Ed.2) to EN 60079-26:2015 (Ed.3) waived. All applicable EPL Ga requirements are included in EN 60079-0:2012+A11:2013 / EN 60079-11:2012.

**Description of Product:**

Power Supply - Gateway type D2050M-\*\*\* provide dual channel two wire intrinsically safe power supply for fieldbus apparatus according to FISCO Model and bi-directional transmission of fieldbus data signals between non intrinsically safe and intrinsically safe fieldbus circuits.

Electronic components of the power supply are arranged on a printed-circuit-board (PCB) packaged in the bottom part of a plastic enclosure suitable for installation on T35 DIN Rails. The PCBs are protected by means of a metallic cover.

Terminals for the intrinsically safe fieldbus supply and signal circuits and for the non-intrinsically safe circuits are arranged on the front side of the enclosure.

Power Supply - Gateway type D2050M-\*\*\* provide safe galvanic separation between intrinsically safe fieldbus supply and signal circuits and non-intrinsically safe fieldbus signal circuits and power supply on the PCB up to a sum of peak values of rated voltages of 375 V.

The Power Supply - Gateway type D2050M-\*\*\* is designated for installation in the safe area or optionally in the hazardous area (apparatus category 2G), mounted in an enclosure providing a suitable type of explosion protection.

Electronic components of the 32 Channel Digital Input type D2030M-\*\*\*, the 16 Channel Analogue Input type D2010M-\*\*\* or the 16 Channel Analogue Input Expander type D2011M-\*\*\* respectively, are arranged on printed-circuit-boards (PCB) packaged in the bottom part of a plastic enclosure suitable for installation on T35 DIN Rails. The PCBs are protected by means of a metallic cover.

Terminals for the intrinsically safe circuits (supply + communication and measuring circuits) are arranged on the front side of the enclosure.

Control- and display facilities (LEDs and configuration jumpers) are arranged on the front panel.

Different IS circuits are galvanically separated from each other or interconnected according to the following table.

Apparatus	galvanic separation between		
	supply + communication line 1 and line 2	measuring circuits and supply + communication	measuring circuits from each other
D2030M-***	yes	yes	no
D2010M-***	yes	yes	no
D2011M-***	yes *)	yes	no

\*) interconnected to D2010M-\*\*\*; D2011M-\*\*\* supplied by D2010M-\*\*\*

Listing of all components used referring to older standards: not applicable.

### 15.3 Parameters

#### 15.3.1 Power Supply-Gateway Type D2050M-\*\*\*

##### 15.3.1.1 Non-intrinsically safe circuits

Parameters	Power supply	Input / output signal circuits
Voltage	$U_n$	DC 24 V (20 - 30 V)
	$U_m$	AC 253 V
Power consumption	$P_n$	8.5 W
Terminals	M4	M2, M3, J3, J4

#### 15.3.2 Intrinsically safe supply- and fieldbus circuits type of protection Ex ia IIC

Parameters	Line 1	Line 2
Voltage $U_o$	DC 15 V	DC 15 V
Current $I_o$	210 mA	210 mA
Supply current at 15 V	116 mA	116 mA
Power $P_o$	1736 mW	1736 mW
Internal effective capacitance $C_i$	complies with FISCO requirements	
Internal effective inductance $L_i$	complies with FISCO requirements	
Current limiting resistor	163 Ω	163 Ω
Characteristics	trapezoidal	
Maximum cable length	see 4.3	see 4.3
Terminals	M1A	M1B

##### 15.3.1.3 Ambient temperature range $-40^{\circ}\text{C} \leq T_a \leq 60^{\circ}\text{C}$

### 15.3.2 Intrinsically safe field devices

#### 15.3.2.1 Power supply

Parameters	D2010M-***, D2010M-*** + D2011M-***, D2030M-***	
	Line 1	Line 2
Voltage $U_i$	DC 15 V	DC 15 V
Current $I_i$	215 mA	215 mA
Power $P_i$	1755 mW	1755 mW
Internal effective capacitance $C_i$	complies with FISCO requirements	
Internal effective inductance $L_i$	complies with FISCO requirements	
Terminals	M10A	M10B
Terminator	1.2 $\mu$ F + 100 $\Omega$	1.2 $\mu$ F + 100 $\Omega$
Terminals	M9A	M9B

#### 15.3.2.2 Measuring circuits

Parameters	D2010M-*** + D2011M-***		D2030M-***	
	Channel 1 - 64		Channel 1 - 32	
Voltage $U_o$	DC 10.7 V		DC 10.7 V	
Current $I_o$	7 mA		14 mA	
Power $P_o$	19 mW		38 mW	
Max. external capacitance $C_o$	IIC	2.23 $\mu$ F	IIC	2.23 $\mu$ F
	IIB	15.6 $\mu$ F	IIB	15.6 $\mu$ F
	IIA	69 $\mu$ F	IIA	69 $\mu$ F
Max. external inductance $L_o$	IIC	725 mH	IIC	181 mH
	IIB	2902 mH	IIB	725 mH
	IIA	5804 mH	IIA	1451 mH
Max. inductance / resistance ratio $L_o/R_o$	IIC	1.888 mH/ $\Omega$	IIC	946.5 $\mu$ H/ $\Omega$
	IIB	7.552 mH/ $\Omega$	IIB	3.786 mH/ $\Omega$
	IIA	15.105 mH/ $\Omega$	IIA	7.572 mH/ $\Omega$
Characteristics	linear			
Terminals	M1 to M8		M1 to M8	

<sup>1)</sup> channel 1 - 16 D2010M-\*\*\* stand alone;  
 channel 17 - 32 first D2011M-\*\*\* expander;  
 channel 33 - 48 second D2011M-\*\*\* expander;  
 channel 49 - 64 third D2011M-\*\*\* expander

#### 15.3.2.3 Ambient temperature range $-40^{\circ}\text{C} \leq T_a \leq 60^{\circ}\text{C}$ .

#### 15.3.3 Maximum cable length

For interconnection cable between Power Supply - Gateway type D2050M-\*\*\* and Field Devices type D2030M-\*\*\* and/or type D2010M-\*\*\* the following parameters apply:

Resistance per unit length:  $15 \Omega/\text{km} \leq R' \leq 150 \Omega/\text{km}$ ;

Inductance per unit length:  $0.4 \text{ mH/km} \leq L' \leq 1 \text{ mH/km}$ ;

Capacitance per unit length (including screen):  $45 \text{ nF/km} \leq C' \leq 200 \text{ nF/km}$ .

$C' = C'_{\text{wire/wire}} + 0.5 \times C'_{\text{wire/screen}}$  fieldbus-circuit insulated.

$C' = C'_{\text{wire/wire}} + C'_{\text{wire/screen}}$  screen connected to the output of the fieldbus power supply.

Maximum length of each spur cable:  $60 \text{ m}$  (Group IIC / IIB).

Maximum permissible cable length including length of all spur cables is  $1000 \text{ m}$  (Group IIC) or  $5000 \text{ m}$  (Group IIB) respectively.

16 **Report Number**

BVS PP 06.2133 EU, as of 2018-05-29

17 **Special Conditions for Use**

## 17.1 Power Supply - Gateway type D2050M-\*\*\*

## 17.1.1 Installation in the safe area.

Wiring shall satisfy the conditions of clause 6.3.12 and clause 7.6.e of EN 60079-11:2012.

Clearances of un-insulated conductors of intrinsically safe circuits to grounded metal parts of the enclosure shall be at least 3 mm, and to un-insulated conductors of non-intrinsically safe circuits of other apparatus shall comply with the values given in table 5 EN 60079-11:2012 as a minimum.

Terminals or connectors for the intrinsically safe fieldbus supply and signal circuits shall be arranged according to clause 6.2.1 or 6.2.2 of EN 60079-11:2012 respectively.

## 17.1.2 Installation in the hazardous area requiring EPL Gb equipment.

The Power Supply - Gateway type D2050M-\*\*\* shall be mounted in an enclosure providing a suitable type of explosion protection.

Mounting in an enclosure providing a suitable type of explosion protection, shall be submitted to separate assessment and/or certification procedure.

## 17.1.3 For interconnection cable between Power Supply - Gateway type D2050M-\*\*\* and Field Devices type D2030M-\*\*\* and/or type D2010M-\*\*\* the parameters in clause 15.3 apply.

## 17.2 Intrinsically safe apparatus type D2030M-\*\*\* / D2010M-\*\*\* / D2011M-\*\*\*.

The backplane of the field devices type D2030M-\*\*\* / D2010M-\*\*\* / D2011M-\*\*\* shall be protected against electrostatic charge by means of suitable installation on DIN rails, if not mounted inside stainless steel enclosure of type series GM23xx.

18 **Essential Health and Safety Requirements**

The Essential Health and Safety Requirements are covered by the standards listed under item 9.

19 **Drawings and Documents**


Drawings and documents are listed in the confidential report.

---

We confirm the correctness of the translation from the German original.

In the case of arbitration only the German wording shall be valid and binding.

DEKRA EXAM GmbH  
Bochum, dated 2018-05-29  
BVS-Scha/Nu A 20160864

  
Certifier  
Approver