

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20130115-E222308C  
**Report Reference** E222308-20110130  
**Issue Date** 2013-JANUARY-15

**Issued to:** G M INTERNATIONAL S R L  
VIA SAN FIORANO 70  
20852 VILLASANTA MB ITALY

**This is to certify that  
representative samples of**

PROCESS CONTROL EQUIPMENT FOR USE IN  
HAZARDOUS LOCATIONS; PROCESS CONTROL  
EQUIPMENT FOR USE IN ZONE CLASSIFIED  
HAZARDOUS


See addendum for models.

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** See addendum for Standards.

**Additional Information:** See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)



# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20130115-E222308C  
**Report Reference** E222308-20110130  
**Issue Date** 2013-JANUARY-15

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

## MODELS:

Associated Apparatus for use in Class I, Division 2, Groups A, B, C, and D Hazardous Locations.

Analog input isolators Models D1010S and D1010D, may or may not be followed by /B, provide intrinsically safe circuits for use in Class I, Groups A, B, C, and D; Class II, Groups E, F, and G; and Class III Hazardous Locations when installed in accordance with manufacturer's control drawing no. ISM0125.

Analog output isolators Models D1020S and D1020D, may or may not be followed by /B, provide intrinsically safe circuits for use in Class I, Groups A, B, C, and D; Class II, Groups E, F, and G; and Class III Hazardous Locations when installed in accordance with manufacturer's control drawing no. ISM0127.

Associated Apparatus for use in Class I, Zone 2, AEx nC [ia] IIC; Class I, Zone 2, Ex nC [ia] IIC Hazardous Locations.

Analog input isolators Models D1010S and D1010D, may or may not be followed by /B, provide intrinsically safe circuits for use in Class I, Zone 0, Group IIC Hazardous Locations when installed in accordance with manufacturer's control drawing no. ISM0125.

Analog output isolators Models D1020S and D1020D, may or may not be followed by /B, provide intrinsically safe circuits for use in Class I, Zone 0, Group IIC Hazardous Locations when installed in accordance with manufacturer's control drawing no. ISM0127.



William R. Carney, Director, North American Certification Programs

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)



# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20130115-E222308C  
**Report Reference** E222308-20110130  
**Issue Date** 2013-JANUARY-15

## STANDARDS:

UL 913, Intrinsically Safe Apparatus and Associated Apparatus for Use in Class I, II, and III, Division 1, Hazardous (Classified) Locations  
UL 1604, Electrical Equipment for Use in Class I and II, Division 2, and Class III Hazardous (Classified) Locations  
UL 60079-0, Electrical Apparatus for Explosive Gas Atmospheres – Part 0: General Requirements  
UL 60079-11, Electrical Apparatus for Explosive Gas Atmospheres – Part 11: Intrinsic Safety “i”  
UL 60079-15, Electrical Apparatus for Explosive Gas Atmospheres – Part 15: Electrical Apparatus with Type of Protection “n”  
UL 61010-1, Electrical Equipment For Measurement, Control, and Laboratory Use; Part 1: General Requirements  
CSA C22.2 No. 157-92, Intrinsically Safe and Non-incendive Equipment for Use in Hazardous Locations  
CSA C22.2 No. 213, Non-incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations  
CSA-E60079-0:02, Electrical apparatus for explosive gas atmospheres – Part 0: General requirements  
CSA-E60079-11:02, Electrical apparatus for explosive gas atmospheres – Part 11: Intrinsic safety “i”  
CSA E60079-15:02, Electrical apparatus for explosive gas atmospheres - Part 15: Type of protection “n”  
CSA C22.2 No. 61010-1-04, Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use - Part 1: General Requirements



William R. Carney, Director, North American Certification Programs

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)

