

CERTIFICATE OF COMPLIANCE

Certificate Number E222308
Report Reference E222308-20200226
Issue Date 2020-FEBRUARY-28

Issued to: G M INTERNATIONAL S R L
Via G. Mameli, 53-55
20852 Villasanta Mb, ITALY

This certificate confirms that representative samples of

PROCESS CONTROL EQUIPMENT FOR USE IN HAZARDOUS LOCATIONS

See Addendum.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety:

UL 61010-1 & CAN/CSA C22.2 No.61010-1-12, Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use - Part 1: General Requirements.

UL 121201 & CSA C22.2 NO.213-17, Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations.

Additional Information:

See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number E222308
Report Reference E222308-20200226
Issue Date 2020-FEBRUARY-28

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

USL, CNL – Open type, Relay Output Module: D5094, D5095 and D5097 series, followed by S, may be followed by “-XXX”, where –XXX are any alpha-numeric characters for use in Class I, Division 2, Groups A, B, C and D, Hazardous Locations.

USL, CNL – Open type, Relay Output Module: D5096 series, followed by S, may be followed by “-100” or by “-XXX”, where –XXX are any alpha-numeric characters for use in Class I, Division 2, Groups A, B, C and D, Hazardous Locations.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

